

Installation and User Manual

13A and 16A Plug-in Timers

Specification

Voltage	230-250v
Switching current	230v 16A & 32A Units 40A (AC-7a) resistive, 15A (AC-7b) inductive 415v 16A & 32A Units 63A (AC-7a) resistive, 20A (AC-7b) inductive Double pole switched contacts
IP rating	Timer enclosure IP55 (when front cover is closed) CEE 60309 connectors - IP44
Accuracy	≤ 1 sec/day at 25°C
Back up	Built in lithium ion battery with 3yr reserve
Max on/off timings	16 x on and off timing cycles
Minimum interval between on/off times	1 min

Operating Instructions

Setting the time	Press and <u>hold</u> the  button Press D+ to select the date Press H+ to select the hour Press M+ to select the minute When the date and time have been entered, release the  button
Change between 12hr/24hr format	Press the  button for 3 secs to alternate between the 12 and 24 hour time format
Setting a time interval	Press the P button repeatedly to reach the timing setting required. There are 16 programmable time periods, numbered 1 to 16. The ON time is shown first. Pressing the P button again shows the OFF time. Where no time is currently programmed, the display will show - - : - - When you reach the time setting required: Press D+ to select the date. Single days of the week and groups of days are available Press H+ to select the hour Press M+ to select the minute To clear a time scroll to the require interval time and then press the MANUAL button.
Override	Press the MANUAL button to alternate between permanently off, permanently on and automated (controlled by the timer)
Factory setting reset	Press the RESET button

